

GOVERNMENT OF ARUNACHAL PRADESH OFFICE OF THE FIRE STATION EAST KAMENG DISTRICT SEPPA

OC

NO.SPA/FS/INSP-23/PP/2021

Dated Seppa the 2nd Sept'2022

// PROVISIONAL FIRE SAFETY CERTIFICATE //

Certified that after having inspection conducted by the Inspection Officer of Fire Station Seppa on 08/11/2022 and report submitted thereafter to this office of Fire Station, Seppa has No Objection to run the KGBV School, Nangnyo under Pakke Kessang. Subject to complied Fire prevention and Fire Safety requirements in accordance with APBBL-2019. This Certificate is valid for a period of 01 (one) year only from the date of Issue.

Condition for the validity of Fire Safety Certificate as under:

- All the Fire Extinguishers & fire installation must be kept in working condition.
- 2. All the means of escape shall be kept free from any kind of obstruction.
- 3. Three Nos. Hose Reel Hose with 2 HP pump must be fitted and connected to the Hose Reels.
- 4. Ground level water tank 20,000 liters capacity must be constructed in nearby School prem
- 5. Apply for renewal of the NOC one month prior to its expiry along with a copy of this Certificate.

Hence you are instructed above mentioned FFE to be installed in the School premises in tenure period. After installation of the requirements you may informed to the undersigned for further inspection.

> (P.Ch. ROY) SO, Officer In-charge,

Fire Station Seppa.

Fire Station

Wast Kameng District

Sepac

Manager

KGBV Pakke Kessang

Swannied With CamScanner

Chairman

Chairman Sei Donyi Charitable Trust Seppa

HEADMISTRESS ****
KGBV Pakke Kessang

L Nargnyo